

ASBESTOS-CONTAINING MATERIALS SURVEY

**3M EAST SIDE PLANT
BUILDING 42
900 BUSH AVENUE
ST. PAUL, MINNESOTA**

IHSC PROJECT NUMBER M07-493

Prepared by:

**INDUSTRIAL HYGIENE SERVICES CORPORATION
4205 White Bear Parkway, Suite 500
Vadnais Heights, Minnesota, MN 55110
(651) 766-9811**

August 30, 2007

TABLE OF CONTENTS

1.0	EXECUTIVE SUMMARY	1
2.0	INTRODUCTION	1
3.0	ASBESTOS BULK SAMPLES RESULTS	2
4.0	METHODOLOGY	3
5.0	LIMITATIONS OF ASBESTOS SURVEY/REMARKS	3

List of Appendices

- Appendix A: Asbestos Material Tables
- Appendix B: Floor Plans of Sample Locations
- Appendix C: Asbestos Analytical Results
- Appendix D: Asbestos Inspector Certifications

ASBESTOS-CONTAINING MATERIALS SURVEY

**3M EAST SIDE PLANT - BUILDING 42
900 BUSH AVENUE
ST. PAUL, MINNESOTA 55133
IHSC PROJECT NUMBER M07-493**

1.0 EXECUTIVE SUMMARY

Industrial Hygiene Services Corporation (IHSC) conducted a building inspection for accessible asbestos-containing materials (ACM) in Building 42 at the 3M East Side Plant at 900 Bush Avenue, St. Paul, Minnesota. The inspection was performed to identify and quantify accessible materials that are known to contain, or are suspect of containing asbestos. The inspection did not include destructive sampling techniques and only accessible building materials were evaluated. Mr. Dan Meier, 3M Installation Services, requested IHSC's services.

Suspect materials identified and sampled included: various pipe insulation, various pipe fittings, cork wallboard and adhesive, wall plaster, cork, tar adhesive, various ceiling tiles and adhesives, various floor tiles and adhesives, various baseboard adhesives, ceramic tile adhesive, black sink undercoating, textures wall paper, gray floor till, transite panels, black window glazing, white window glazing, Tar on duct insulation, and brown duct adhesive.

Some materials were inferred from previous surveys. Materials inferred included most pipe insulation and fittings, and fireproofing. IHSC also assumed a few materials to be asbestos containing. IHSC assumed the following materials to contain asbestos; sheetrock and joint compound, plaster walls and ceilings. Materials not specifically referred to in this report should be presumed to be ACM until sampling and analysis proves them to be otherwise.

Details of the survey findings including location, material identification, physical identification, quantities and sample results are presented on the enclosed tables in Appendix A, Asbestos Material Tables. Drawings of sample locations are contained in Appendix B.

2.0 INTRODUCTION

Industrial Hygiene Services Corporation (IHSC) was contracted to perform an inspection for known and suspect ACM at 900 Bush Avenue, St. Paul, Minnesota. The purpose of the survey was to define suspect asbestos-containing materials at Building 42 of the 3M East Side Plant.

The survey and sampling was performed to identify and estimate the quantity of ACM at Building 42. The inspection was performed using nondestructive sampling techniques. Accessible interior

building materials and components were inspected. Tom Sogard, John Martin, Karen Malkowski, Terry Johnson, Dave Plourde, Tim Schmit and Matt Lenz of IHSC performed the building survey between June 1 and June 22, 2007. IHSC collected approximately ninety building material samples. IHSC sampled the various pipe insulation, various pipe fittings, cork wallboard and adhesive, wall plaster, cork, tar adhesive, various ceiling tiles and adhesives, various floor tiles and adhesives, various baseboard adhesives, ceramic tile adhesive, black sink undercoating, textures wall paper, gray floor till, transite panels, black window glazing, white window glazing, Tar on duct insulation, and brown duct adhesive. Results can be found in the enclosed tables in Appendix A, Asbestos Material Tables and in Appendix C, Asbestos Analytical Results.

The roofing materials were not sampled at the time of the inspection. Roofing materials should be assumed to contain asbestos until sampling verifies otherwise.

3.0 ASBESTOS BULK SAMPLE RESULTS

Representative bulk samples of suspect materials were collected throughout Building 42. Materials found to contain asbestos included:

- Various Pipe Insulation (Some sampled others inferred)
- Various Pipe Fitting Insulation (Some sampled others inferred)
- Fireproofing (Inferred)
- Cork Wall Adhesive
- Basement Wall Plaster
- Brown Ceiling Tile Adhesive
- Various Floor Tiles and Adhesive
- Black Sink Undercoating
- Gray Floor Till
- Transite Panels
- Black Window Glazing
- White Window Glazing
- Tarpaper on Fiberglass Duct
- Tar on Fiberglass Duct Insulation
- Sheetrock and Joint Compound (Assumed)
- Plaster Walls and Ceilings (Assumed)

The materials above were found to contain asbestos using Environmental Protection Agency (EPA) definitions. Materials not specifically referred to in this report should be presumed to be ACM until sampling and analysis proves them to be otherwise.

Locations, materials identification, physical identification, quantities, and analytical results are summarized in Appendix A, Asbestos Material Tables. Sample locations are summarized in Appendix B, Floor Plans of Sample Locations.

4.0 METHODOLOGY

Suspect ACM was categorized into three (3) principle material groupings: surfacing material, (sprayed-on or troweled-on material) thermal system insulation, or miscellaneous materials (e.g. flooring, ceiling tiles, wallboards).

Suspect ACM was further categorized into homogeneous-material types. A homogeneous-material type is defined as a suspect ACM that has the same visual appearance (same color, texture, and pattern) and appeared to be installed during the same general period of time. Materials are also categorized as friable or non-friable; friable materials are those that can be crushed, pulverized, or reduced to a powder by hand pressure when dry.

IHSC personnel who performed the building survey and sampling have completed, at a minimum, an EPA-approved training course in Asbestos Survey and the applicable refresher training courses. Copies of the asbestos inspector certifications are enclosed in Appendix D.

5.0 LIMITATIONS OF ASBESTOS SURVEY/REMARKS

Any discussion or recommendations contained in this report represent our professional opinions. These opinions are based on currently available information and are arrived at in accordance with currently accepted industrial hygiene practices at this time and location. Other than this, no guarantee is implied or intended.


Every effort was made to completely identify suspect materials using non-destructive techniques at Building 42, 900 Bush Avenue, St. Paul, Minnesota. Evaluation was based on past experience with similar materials, similar buildings, similar budgeting, and time constraints. Inspection of these areas may be necessary for renovation or demolition. IHSC maintains that materials observed and quantified are factual and accurate.

Asbestos-Containing Material Survey
3M East Side Plant – Building 42
St. Paul, Minnesota
IHSC Project Number: M07-493
August 30, 2007

Page 4 of 3

This report was prepared by

INDUSTRIAL HYGIENE SERVICES CORPORATION



Date: 8/30/07

Nicholas S. Mueller

Project Manager

Minnesota Department of Health Asbestos Inspector Card Number AI3806

APPENDIX A

ASBESTOS MATERIAL TABLES

Building Name: Building 42, 3M Main Plant

IHSC Project No.: M07-493

Survey Date: July 24, 2007



INDUSTRIAL
HYGIENE
SERVICES
CORPORATION

Location	Material Identification	Physical ID	Quantity	Units	Sample #	Results
----------	-------------------------	-------------	----------	-------	----------	---------

Basement

West Mechanical Room	1-4" Pipe Insulation	White Fibrous	306	Linear Feet	B0313	10%Chrysotile 40%Amosite
	1-4" Pipe Fitting Insulation on White Fibrous	White Fibrous	39	Each	B0316	24%Chrysotile 16%Amosite
	> 4" Pipe Insulation	White Fibrous	626	Linear Feet	B0307	18%Chrysotile 32%Amosite
	> 4" Pipe Fitting Insulation on White Fibrous	White Fibrous	65	Each	B0310	20%Chrysotile 25%Amosite
	1-4" Pipe Insulation	Felt	70	Linear Feet	B0337	18%Chrysotile
	1-4" Pipe Fitting Insulation on Felt	Gray Fibrous	4	Each	B0341	9%Chrysotile 18%Amosite
	> 4" Pipe Insulation	Felt	114	Linear Feet	B0331	3%Chrysotile
	> 4" Pipe Fitting Insulation on Felt	Gray Fibrous	1	Each	B0334	13%Chrysotile 16%Amosite
	1-4" Pipe Fitting Insulation on Fiberglass	Gray Fibrous	6	Each	B0341	9%Chrysotile 18%Amosite
	> 4" Pipe Fitting Insulation on Fiberglass	Gray Fibrous Cork	13	Each	1A	None Detected
	> 4" Pipe Insulation	Cork	311	Linear Feet	B0326	None Detected
	> 4" Pipe Fitting Insulation on Cork	Gray Fibrous	12	Each	B0328	17%Chrysotile 16%Amosite
	Fireproofing	Ceiling	5126	Square Feet	B0284	12%Chrysotile
	Plaster	Wall	3840	Square Feet	4A	2% Chrysotile (3% white layer)
	Cork Wall	Under Plaster	3840	Square Feet	2A	None Detected

* = This result is inferred as consistent with an analyzed sample of the same material from another area.
NSMO = No Suspect Materials Observed.
Samples starting with B are samples taken in previous surveys.

Location	Material Identification	Physical ID	Quantity	Units	Sample #	Results
	Cork Adhesive	Black	3840	Square Feet	3A	3% Chrysotile
East Mechanical Room	1-4" Pipe Insulation	White Fibrous	492	Linear Feet	B0313	10%Chrysotile 40%Amosite
	1-4" Pipe Fitting Insulation on White Fibrous	White Fibrous	56	Each	B0316	24%Chrysotile 16%Amosite
	> 4" Pipe Insulation	White Fibrous	198	Linear Feet	B0307	18%Chrysotile 32%Amosite
	> 4" Pipe Fitting Insulation on White Fibrous	White Fibrous	24	Each	B0310	20%Chrysotile 25%Amosite
	1-4" Pipe Insulation	Felt	600	Linear Feet	B0337	18%Chrysotile
	1-4" Pipe Fitting Insulation on Felt	Gray Fibrous	57	Each	B0341	9%Chrysotile 18%Amosite
	> 4" Pipe Insulation	Felt	78	Linear Feet	B0369	11%Chrysotile
	> 4" Pipe Fitting Insulation on Felt	Gray Fibrous	7	Each	B0372	60%Chrysotile 5%Amosite
	> 4" Pipe Insulation	Cork	269	Linear Feet	B0326	None Detected
	> 4" Pipe Fitting Insulation on Cork	Gray Fibrous	13	Each	B0328	17%Chrysotile 16%Amosite
	Fireproofing	Ceiling	4583	Square Feet	B0358	25%Chrysotile
	Plaster	Wall	1935	Square Feet	4*	2% Chrysotile (3% white layer)
	Cork Wall	Under Plaster	1935	Square Feet	2*	None Detected
	Cork Adhesive	Black	1935	Square Feet	3*	3% Chrysotile
	Tar Paper on Fiberglass	On Ducting	180	Square Feet	74A	5% Chrysotile
	Electrical Room	1-4" Pipe Insulation	White Fibrous	21	Linear Feet	B0313
1-4" Pipe Fitting Insulation on White Fibrous		White Fibrous	12	Each	B0316	24%Chrysotile 16%Amosite
> 4" Pipe Insulation		White Fibrous	26	Linear Feet	B0307	18%Chrysotile 32%Amosite
> 4" Pipe Fitting Insulation on White Fibrous		White Fibrous	3	Each	B0310	20%Chrysotile 25%Amosite
Plaster		Wall	375	Square Feet	4*	2% Chrysotile (3% white layer)

* = This result is inferred as consistent with an analyzed sample of the same material from another area.
NSMO = No Suspect Materials Observed.
Samples starting with B are samples taken in previous surveys.

Location	Material Identification	Physical ID	Quantity	Units	Sample #	Results
	Cork Wall	Under Plaster	375	Square Feet	2*	None Detected
	Cork Adhesive	Black Wall	375	Square Feet	3*	3% Chrysotile
	Sheetrock	Wall	81	Square Feet	Not Sampled	Assumed Asbestos
West Mech. Rm. Entrance	2' x 4' Ceiling Tile	Pinhole Fissure	60	Square Feet	27A	None Detected
	12" x 12" Floor Tile	Brown Mottled Black	98	Square Feet	55A	None Detected
	Floor Tile Adhesive	Black	98	Square Feet	56A	7% Chrysotile
	Plaster (Smooth)	Wall and Ceiling	626	Square Feet	4A	2% Chrysotile (3% white layer)
	Base Board Adhesive	Brown	42	Linear Feet	62A	None Detected
	Floor Fill	Gray	98	Square Feet	68A	10% Chrysotile
	1-4" Pipe Insulation	Felt	42	Linear Feet	B0337	18%Chrysotile
West Mech. Rm. Bathroom	Plaster (Smooth)	Wall and Ceiling	626	Square Feet	4*	2% Chrysotile (3% white layer)
West Mech. Rm. Bathroom Pipe Chase	1-4" Pipe Insulation	Felt	40	Linear Feet	B0337	18%Chrysotile
	1-4" Pipe Fitting Insulation on Felt	Gray Fibrous	6	Each	B0341	9%Chrysotile 18%Amosite
Women's Restroom	Plaster (Smooth)	Wall and Ceiling	206	Square Feet	4A	2% Chrysotile (3% white layer)
Office 1	9" x 9" Floor Tile	Brown w/ Orange	144	Square Feet	32A	4% Chrysotile
	Floor Tile Adhesive	Black Wall	144	Square Feet	33A	10% Chrysotile
	Sheetrock	Tan	480	Square Feet	Not Sampled	Assumed Asbestos
	Base Board Adhesive	Longitudinal PH Fissure	12	Linear Feet	61*	None Detected
	2' x 4' Ceiling Tile		144	Square Feet	29A	None Detected
Office 2	9" x 9" Floor Tile	Brown w/ Orange	144	Square Feet	32*	4% Chrysotile
	Floor Tile Adhesive	Black Wall	144	Square Feet	33*	10% Chrysotile
	Sheetrock	Tan	480	Square Feet	Not Sampled	Assumed Asbestos
	Base Board Adhesive	Longitudinal PH Fissure	24	Linear Feet	61*	None Detected
	2' x 4' Ceiling Tile		144	Square Feet	29*	None Detected

* = This result is inferred as consistent with an analyzed sample of the same material from another area.
NSMO = No Suspect Materials Observed.
Samples starting with B are samples taken in previous surveys.

Location	Material Identification	Physical ID	Quantity	Units	Sample #	Results
Office 3	9" x 9" Floor Tile Floor Tile Adhesive Sheetrock Base Board Adhesive 2' x 4' Ceiling Tile	Brown w/ Orange Black Wall Tan Longitudinal PH Fissure	88	Square Feet	32*	4% Chrysotile
			88	Square Feet	33*	10% Chrysotile
			380	Square Feet	Not Sampled	Assumed Asbestos
			19	Linear Feet	61A	None Detected
			88	Square Feet	29*	None Detected
Office 4	9" x 9" Floor Tile Floor Tile Adhesive Sheetrock Base Board Adhesive 2' x 4' Ceiling Tile	Brown w/ Orange Black Wall Tan Longitudinal PH Fissure	132	Square Feet	32*	4% Chrysotile
			132	Square Feet	33*	10% Chrysotile
			460	Square Feet	Not Sampled	Assumed Asbestos
			12	Linear Feet	61*	None Detected
			132	Square Feet	29*	None Detected
Conference Room	9" x 9" Floor Tile Floor Tile Adhesive Sheetrock Base Board Adhesive 2' x 4' Ceiling Tile	Brown w/ Orange Black Wall Tan Longitudinal PH Fissure	418	Square Feet	32*	4% Chrysotile
			418	Square Feet	33*	10% Chrysotile
			800	Square Feet	Not Sampled	Assumed Asbestos
			22	Linear Feet	61*	None Detected
			418	Square Feet	29*	None Detected
Open Office Area	9" x 9" Floor Tile Floor Tile Adhesive Sheetrock Base Board Adhesive 2' x 4' Ceiling Tile 1-4" Pipe Insulation > 4" Pipe Insulation	Brown w/ Orange Black Wall Tan Longitudinal PH Fissure Felt Cork	1976	Square Feet	32*	4% Chrysotile
			1976	Square Feet	33*	10% Chrysotile
				Square Feet	Not Sampled	Assumed Asbestos
			132	Linear Feet	61*	None Detected
			308	Square Feet	29*	None Detected
	Linear Feet	B0337	18% Chrysotile			
	Linear Feet	B0326	None Detected			
East Corridor	9" x 9" Floor Tile Floor Tile Adhesive Sheetrock Base Board Adhesive	Brown w/ Orange Black Wall Tan	300	Square Feet	32*	4% Chrysotile
			300	Square Feet	33*	10% Chrysotile
			1200	Square Feet	Not Sampled	Assumed Asbestos
			120	Linear Feet	61*	None Detected

* = This result is inferred as consistent with an analyzed sample of the same material from another area.
NSMO = No Suspect Materials Observed.
Samples starting with B are samples taken in previous surveys.

Location	Material Identification	Physical ID	Quantity	Units	Sample #	Results
East Corridor	2' x 4' Ceiling Tile	Longitudinal PH Fissure	300	Square Feet	29*	None Detected
	1-4" Pipe Insulation	Felt	54	Linear Feet	B0337	18%Chrysotile
	1-4" Pipe Fitting Insulation on Felt	Gray Fibrous	2	Each	B0341	9%Chrysotile
	> 4" Pipe Insulation	Cork	30	Linear Feet	B0326	18%Amosite
	> 4" Pipe Fitting Insulation on Cork	Gray Fibrous	3	Each	B0328	None Detected 17%Chrysotile 16%Amosite
South Corridor	9" x 9" Floor Tile	Brown w/ Orange	392	Square Feet	32*	4% Chrysotile
	Floor Tile Adhesive	Black	392	Square Feet	33*	10% Chrysotile
	Sheetrock	Wall	1120	Square Feet	Not Sampled	Assumed Asbestos
	Base Board Adhesive	Tan	224	Linear Feet	61*	None Detected
	2' x 4' Ceiling Tile	Longitudinal PH Fissure	392	Square Feet	29*	None Detected
Wall Hatch	NSMO					
Deli	Sheetrock	Wall and Ceiling	1596	Square Feet	Not Sampled	Assumed Asbestos
	Sink Undercoat	Black Felt	1	Each	66A	2% Chrysotile
	1-4" Pipe Insulation	Gray Fibrous	90	Linear Feet	B0337	18%Chrysotile
	1-4" Pipe Fitting Insulation on Felt	Cork	8	Each	B0341	9%Chrysotile
	> 4" Pipe Insulation	Gray Fibrous	48	Linear Feet	B0326	18%Amosite
	> 4" Pipe Fitting Insulation on Cork	White Fibrous	2	Each	B0328	None Detected
	1-4" Pipe Insulation	White Fibrous	36	Linear Feet	B0313	17%Chrysotile
> 4" Pipe Insulation	White Fibrous	72	Linear Feet	B0307	16%Amosite 10%Chrysotile 40%Amosite 18%Chrysotile 32%Amosite	
Elevator Lobby	Sheetrock	Wall	1120	Square Feet	Not Sampled	Assumed Asbestos
	2' x 2' Ceiling Tile	Pinhole	408	Square Feet	8A	None Detected
Kitchenette	Sheetrock	Wall	224	Square Feet	Not Sampled	Assumed Asbestos
	2' x 2' Ceiling Tile	Sheetrock	480	Square Feet	24A	None Detected

* = This result is inferred as consistent with an analyzed sample of the same material from another area.
NSMO = No Suspect Materials Observed.
Samples starting with B are samples taken in previous surveys.

Location	Material Identification	Physical ID	Quantity	Units	Sample #	Results
Wall Hatch	NSMO					
Dining Room Storage	Sheetrock 2' x 2' Ceiling Tile	Wall Pinhole	378 110	Square Feet Square Feet	Not Sampled 8*	Assumed Asbestos None Detected
Wall Hatch	NSMO					
Cafeteria	Sheetrock 2' x 2' Ceiling Tile 1-4" Pipe Insulation > 4" Pipe Insulation	Wall and Ceiling Pinhole Felt Cork	3656 3338 328 164	Square Feet Square Feet Linear Feet Linear Feet	Not Sampled 8* B0337 B0326	Assumed Asbestos None Detected 18%Chrysotile None Detected
Cafeteria Hallway	Sheetrock 2' x 2' Ceiling Tile 1-4" Pipe Insulation 1-4" Pipe Fitting Insulation on Felt > 4" Pipe Insulation > 4" Pipe Fitting Insulation on Felt 1-4" Pipe Insulation	Wall Pinhole Felt Gray Fibrous Felt Gray Fibrous White Fibrous	720 1620 6 2 19 6 180	Square Feet Square Feet Linear Feet Each Linear Feet Each Linear Feet	Not Sampled 8* B0337 B0341 B0331 B0334 B0313	Assumed Asbestos None Detected 18%Chrysotile 9%Chrysotile 18%Amosite 3%Chrysotile 13%Chrysotile 16%Amosite 10%Chrysotile 40%Amosite
Kitchen Hallway	1-4" Pipe Insulation 1-4" Pipe Fitting Insulation on White Fibrous 1-4" Pipe Insulation 1-4" Pipe Fitting Insulation on Felt Plaster (Smooth)	White Fibrous White Fibrous Felt Gray Fibrous Wall and Ceiling	214 24 21 7 626	Linear Feet Each Linear Feet Each Square Feet	B0313 B0316 B0337 B0341 Not Sampled	10%Chrysotile 40%Amosite 24%Chrysotile 16%Amosite 18%Chrysotile 9%Chrysotile 18%Amosite Assumed Asbestos
Kitchen Men's Restroom	Plaster (Smooth)	Wall and Ceiling	626	Square Feet	Not Sampled	Assumed Asbestos
Kitchen Women Restroom	Plaster (Smooth)	Wall and Ceiling	626	Square Feet	Not Sampled	Assumed Asbestos

* = This result is inferred as consistent with an analyzed sample of the same material from another area.
NSMO = No Suspect Materials Observed.
Samples starting with B are samples taken in previous surveys.

Location	Material Identification	Physical ID	Quantity	Units	Sample #	Results
Kitchen Restroom Pipe Chase	1-4" Pipe Insulation	Felt	23	Linear Feet	B0337	18%Chrysotile 9%Chrysotile 18%Amosite 10%Chrysotile 40%Amosite
	1-4" Pipe Fitting Insulation on Felt	Gray Fibrous	9	Each	B0341	
	1-4" Pipe Insulation	White Fibrous	18	Linear Feet	B0313	
Kitchen Locker Room	Plaster (Smooth)	Wall and Ceiling	178	Square Feet	Not Sampled	Assumed Asbestos Assumed Asbestos None Detected None Detected 3% Chrysotile
	Sheetrock	Wall	22	Square Feet	Not Sampled	
	Base Board Adhesive	Brown	50	Linear Feet	62*	
	12" x 12" Floor Tile	Tan w/ Brown and White	42	Square Feet	57A	
	Floor Tile Adhesive	Black	42	Square Feet	58A	
Kitchen Pipe Chase	1-4" Pipe Insulation	Felt	24	Linear Feet	B0337	18%Chrysotile 9% Chrysotile 18%Amosite
	1-4" Pipe Fitting Insulation on Felt	Gray Fibrous	5	Each	B0341	
Private Dining 1	12" x 12" Ceiling Tile	Rough Wall Tan Textured	352	Square Feet	7A	None Detected Assumed Asbestos None Detected None Detected
	Sheetrock		228	Square Feet	Not Sampled	
	Base Board Adhesive		76	Linear Feet	61*	
	Wall Paper		240	Square Feet	67A	
Private Dining 2	12" x 12" Ceiling Tile	Rough Wall Tan	680	Square Feet	7*	None Detected Assumed Asbestos None Detected
	Sheetrock		936	Square Feet	Not Sampled	
	Base Board Adhesive		104	Linear Feet	61*	
Private Dining Prep	1-4" Pipe Insulation	White Fibrous	11	Linear Feet	B0313	10%Chrysotile 40%Amosite 24%Chrysotile 16%Amosite Assumed Asbestos None Detected
	1-4" Pipe Fitting Insulation on White Fibrous	White Fibrous	5	Each	B0316	
	Sheetrock	Wall	684	Square Feet	Not Sampled	
	2' x 2' Ceiling Tile	Sheetrock	352	Square Feet	24*	
Storage	Plaster (Smooth)	Wall	352	Square Feet	Not Sampled	Assumed Asbestos

* = This result is inferred as consistent with an analyzed sample of the same material from another area.
NSMO = No Suspect Materials Observed.
Samples starting with B are samples taken in previous surveys.

Location	Material Identification	Physical ID	Quantity	Units	Sample #	Results
Kitchen	2' x 4' Ceiling Tile	Swirled Pinhole	1444	Square Feet	30A	None Detected
	Tile Adhesive	Tan Ceramic	70	Square Feet	65A	None Detected
	1-4" Pipe Insulation	White Fibrous	48	Linear Feet	B0313	10%Chrysotile 40%Amosite
	1-4" Pipe Insulation	Felt	72	Linear Feet	B0337	18%Chrysotile
	1-4" Pipe Fitting Insulation on Felt	Gray Fibrous	3	Each	B0341	9%Chrysotile 18%Amosite
	> 4" Pipe Insulation	Cork	48	Linear Feet	B0326	None Detected
Kitchen Office	12" x 12" Floor Tile	Tan w/ Brown and White	70	Square Feet	57*	None Detected
	Floor Tile Adhesive	Black	70	Square Feet	58*	3% Chrysotile
	2' x 4' Ceiling Tile	Swirled Pinhole	70	Square Feet	30*	None Detected
Kitchen Serving Area	Sheetrock	Wall	747	Square Feet	Not Sampled	Assumed Asbestos
	2' x 2' Ceiling Tile	Sheetrock	1512	Square Feet	24*	None Detected
Information Center	Sheetrock	Wall	532	Square Feet	Not Sampled	Assumed Asbestos
	2' x 2' Ceiling Tile	Pinhole	342	Square Feet	8*	None detected
	Plaster (Smooth)	Wall	342	Square Feet	Not Sampled	Assumed Asbestos
Private Dining 2	12" x 12" Ceiling Tile	Rough	640	Square Feet	7*	None Detected
	Sheetrock	Wall	1280	Square Feet	Not Sampled	Assumed Asbestos
	Base Board Adhesive	Tan	104	Linear Feet	61*	None Detected
Deli Storage	12" x 12" Floor Tile	Tan w/ Brown and White	144	Square Feet	57*	None Detected
	Floor Tile Adhesive	Black	144	Square Feet	58*	3% Chrysotile
	Sheetrock	Wall	600	Square Feet	Not Sampled	Assumed Asbestos
	Base Board Adhesive	Tan	60	Linear Feet	61*	None Detected
	2' x 2' Ceiling Tile	Textured	144	Square Feet	20A	None Detected
	1-4" Pipe Insulation	White Fibrous	6	Linear Feet	B0313	10%Chrysotile 40%Amosite
	> 4" Pipe Insulation	White Fibrous	12	Linear Feet	B0307	18%Chrysotile 32%Amosite

* = This result is inferred as consistent with an analyzed sample of the same material from another area.
NSMO = No Suspect Materials Observed.
Samples starting with B are samples taken in previous surveys.

Location	Material Identification	Physical ID	Quantity	Units	Sample #	Results
Electrical Room 3	NSMO					
Maintenance Office Storage	9" x 9" Floor Tile	Brown w/ Orange	624	Square Feet	32*	4% Chrysotile
	Floor Tile Adhesive	Black Wall	624	Square Feet	33*	10% Chrysotile
	Sheetrock	Longitudinal PH Fissure	240	Square Feet	Not Sampled	Assumed Asbestos
	2' x 4' Ceiling Tile	Wall	624	Square Feet	29*	None Detected
	Plaster	Under Plaster	390	Square Feet	Not Sampled	Assumed Asbestos
	Cork Wall	Black	390	Square Feet	2*	None Detected
	Cork Adhesive	White Fibrous	390	Square Feet	3*	3% Chrysotile
	1-4" Pipe Insulation	White Fibrous	52	Linear Feet	B0313	10%Chrysotile
	1-4" Pipe Fitting Insulation on White Fibrous	White Fibrous	4	Each	B0316	40%Amosite
	> 4" Pipe Insulation	White Fibrous	52	Linear Feet	B0307	24%Chrysotile 16%Amosite 18%Chrysotile 32%Amosite
Phone Room	Sheetrock	Wall	360	Square Feet	Not Sampled	Assumed Asbestos
	2' x 4' Ceiling Tile	Longitudinal PH Fissure	288	Square Feet	29*	None Detected
	1-4" Pipe Insulation	Felt	36	Linear Feet	B0337	18%Chrysotile
	> 4" Pipe Insulation	Cork	54	Linear Feet	B0326	None Detected
West Storage	Sheetrock	Wall	740	Square Feet	Not Sampled	Assumed Asbestos
	2' x 4' Ceiling Tile	Longitudinal PH Fissure	504	Square Feet	29*	None Detected
	Plaster	Wall	420	Square Feet	Not Sampled	Assumed Asbestos
	Cork Wall	Under Plaster	420	Square Feet	2*	None Detected
	Cork Adhesive	Black	420	Square Feet	3*	3% Chrysotile
	1-4" Pipe Insulation	White Fibrous	36	Linear Feet	B0313	10%Chrysotile
	1-4" Pipe Fitting Insulation on White Fibrous	White Fibrous	2	Each	B0316	40%Amosite
	> 4" Pipe Insulation	White Fibrous	36	Linear Feet	B0307	24%Chrysotile 16%Amosite 18%Chrysotile 32%Amosite

* = This result is inferred as consistent with an analyzed sample of the same material from another area.
NSMO = No Suspect Materials Observed.
Samples starting with B are samples taken in previous surveys.

Location	Material Identification	Physical ID	Quantity	Units	Sample #	Results
1st Floor						
Storage 1	12" x 12" Ceiling Tile	Rough	540	Square Feet	9A	None Detected
	Ceiling Tile Adhesive	Brown	540	Square Feet	10A	5% Anthophyllite
	9" x 9" Floor Tile	Red	540	Square Feet	45A	15% Chrysotile
	Floor Tile Adhesive	Black	540	Square Feet	46A	None Detected
	Sheetrock Plaster	Ceiling Wall	540	Square Feet	Not Sampled	Assumed Asbestos
1-4" Pipe Insulation	Felt	780	Square Feet	Not Sampled	Assumed Asbestos	
	1-4" Pipe Fitting Insulation on Felt	Gray Fibrous	67	Linear Feet	B0337	18%Chrysotile
			14	Each	B0341	9%Chrysotile 18%Amosite
Wall Hatch	1-4" Pipe Insulation	Felt	2	Linear Feet	B0337	18%Chrysotile
	1-4" Pipe Fitting Insulation on Felt	Gray Fibrous	1	Each	B0341	9%Chrysotile 18%Amosite
Storage 2	12" x 12" Ceiling Tile	Deep Fissure	300	Square Feet	15*	None Detected
	Ceiling Tile Adhesive	Tan	300	Square Feet	16*	None Detected
	12" x 12" Ceiling Tile	Fine Pinhole Fissure	274	Square Feet	13*	None Detected
	Ceiling Tile Adhesive	Brown	274	Square Feet	14*	None Detected
	9" x 9" Floor Tile	Gray w/ White and Black	572	Square Feet	47*	7% Chrysotile
	Floor Tile Adhesive	Black	572	Square Feet	48*	15% Chrysotile
	Plaster Sheetrock	Wall and Ceiling Ceiling	480	Square Feet	4*	Assumed Asbestos
			572	Square Feet	Not Sampled	Assumed Asbestos
Wall Hatch	1-4" Pipe Insulation	Felt	10	Linear Feet	B0337	18%Chrysotile
	1-4" Pipe Fitting Insulation on Felt	Gray Fibrous	4	Each	B0341	9%Chrysotile 18%Amosite
	1-4" Pipe Insulation	White Fibrous	24	Linear Feet	B0313	10%Chrysotile 40%Amosite
Ceiling Hatch	1-4" Pipe Insulation	Felt	10	Linear Feet	B0337	18%Chrysotile
	1-4" Pipe Fitting Insulation on Felt	Gray Fibrous	4	Each	B0341	9%Chrysotile 18%Amosite
	Tar Paper	On Ducting	16	Square Feet	Not Sampled	Assumed Asbestos

* = This result is inferred as consistent with an analyzed sample of the same material from another area.
NSMO = No Suspect Materials Observed.
Samples starting with B are samples taken in previous surveys.

Location	Material Identification	Physical ID	Quantity	Units	Sample #	Results
Ceiling Hatch	Tar	On Ducting Seams	32	Square Feet	Not Sampled	Assumed Asbestos
Mail Room	12" x 12" Ceiling Tile	Rough	572	Square Feet	9*	None Detected
	Ceiling Tile Adhesive	Brown	572	Square Feet	10*	5% Anthophyllite
	9" x 9" Floor Tile	Gray w/ White and Black	150	Square Feet	47A	7% Chrysotile
	Floor Tile Adhesive	Black	420	Square Feet	48A	15% Chrysotile
	9" x 9" Floor Tile	Dark Gray	420	Square Feet	49A	5% Chrysotile
	Floor Tile Adhesive	Black	420	Square Feet	50A	10% Chrysotile
	Plaster	Wall and Ceiling	220	Square Feet	Not Sampled	Assumed Asbestos
	Sheetrock	Ceiling	572	Square Feet	Not Sampled	Assumed Asbestos
Above Ceiling	Tar	On Ducting Seams	32	Square Feet	Not Sampled	Assumed Asbestos
Data Room	NSMO					
Wall Hatch	NSMO					
Mail Room Hallway	9" x 9" Floor Tile	Dark Gray	8	Square Feet	49*	5% Chrysotile
	Floor Tile Adhesive	Black	8	Square Feet	50*	10% Chrysotile
	9" x 9" Floor Tile	Tan w/ White	3	Square Feet	34A	3% Chrysotile
	Floor Tile Adhesive	Black	3	Square Feet	35A	4% Chrysotile
	9" x 9" Floor Tile	Gray w/ White and Black	700	Square Feet	47*	7% Chrysotile
	Floor Tile Adhesive	Black	700	Square Feet	48*	15% Chrysotile
	9" x 9" Floor Tile	Brown Mottled	5	Square Feet	40A	None Detected
	Floor Tile Adhesive	Black	5	Square Feet	41A	None Detected
	12" x 12" Ceiling Tile	Deep Fissure	672	Square Feet	15A	None Detected
	Ceiling Tile Adhesive	Tan	672	Square Feet	16A	None Detected
	12" x 12" Ceiling Tile	Fine Pinhole Fissure	332	Square Feet	13A	None Detected
	Ceiling Tile Adhesive	Brown	332	Square Feet	14A	None Detected
	Plaster	Wall and Ceiling	880	Square Feet	Not Sampled	Assumed Asbestos
	Sheetrock	Ceiling	1008	Square Feet	Not Sampled	Assumed Asbestos
Base Board Adhesive	Brown	172	Linear Feet	62*	None Detected	
1-4" Pipe Insulation	Felt	176	Linear Feet	B0337	18% Chrysotile	

* = This result is inferred as consistent with an analyzed sample of the same material from another area.
NSMO = No Suspect Materials Observed.
Samples starting with B are samples taken in previous surveys.

Location	Material Identification	Physical ID	Quantity	Units	Sample #	Results
Mail Room Hallway	1-4" Pipe Fitting Insulation on Felt	Gray Fibrous	20	Each	B0341	9%Chrysotile 18%Amosite
Shipping and Receiving	12" x 12" Ceiling Tile	Deep Fissure	250	Square Feet	15*	None Detected
	Ceiling Tile Adhesive	Tan	250	Square Feet	16*	None Detected
	12" x 12" Ceiling Tile	Fine Pinhole Fissure	250	Square Feet	13*	None Detected
	Ceiling Tile Adhesive	Brown	250	Square Feet	14*	None Detected
	12" x 12" Ceiling Tile	Fine Pinhole Fine Fissure	900	Square Feet	11A	None Detected
	Ceiling Tile Adhesive	Brown	900	Square Feet	12A	2% Anthophyllite
	Plaster	Wall and Ceiling	170	Square Feet	Not Sampled	Assumed Asbestos
	Sheetrock	Ceiling	1848	Square Feet	Not Sampled	Assumed Asbestos
	Base Board Adhesive	Brown	76	Linear Feet	62*	None Detected
	12" x 12" Floor Tile	Brown mottled	1422	Square Feet	55*	None Detected
	Floor Tile Adhesive	Black	1422	Square Feet	56*	7% Chrysotile
	12" x 12" Floor Tile	Cream Mottled	6	Square Feet	59A	None Detected
	Floor Tile Adhesive	Black	6	Square Feet	60A	None Detected
	1-4" Pipe Insulation	White Fibrous	16	Linear Feet	B0313	10%Chrysotile 40%Amosite
1-4" Pipe Fitting Insulation on White Fibrous	White Fibrous	2	Each	B0316	24%Chrysotile 16%Amosite	
B-16 Pipe Chase	1-4" Pipe Insulation	White Fibrous	23	Linear Feet	B0313	10%Chrysotile 40%Amosite
	1-4" Pipe Fitting Insulation on White Fibrous	White Fibrous	6	Each	B0316	24%Chrysotile 16%Amosite
	> 4" Pipe Insulation	White Fibrous	24	Linear Feet	B0307	18%Chrysotile 32%Amosite
	> 4" Pipe Fitting Insulation on White Fibrous	White Fibrous	2	Each	B0310	20%Chrysotile 25%Amosite
Water Storage Room	2' x 4' Ceiling Tile	Pinhole Fissure	98	Square Feet	27*	None Detected
	Sheetrock	Ceiling	336	Square Feet		
	Base Board Adhesive	Tan	42	Linear Feet	61*	None Detected
B-15 Pipe Chase	1-4" Pipe Insulation	Cork	23	Linear Feet	Not Sampled	Assumed Asbestos

* = This result is inferred as consistent with an analyzed sample of the same material from another area.
NSMO = No Suspect Materials Observed.
Samples starting with B are samples taken in previous surveys.

Location	Material Identification	Physical ID	Quantity	Units	Sample #	Results
B-15 Pipe Chase	1-4" Pipe Fitting Insulation on Cork	Gray Fibrous	6	Each	Not Sampled	Assumed Asbestos
Dock	12" x 12" Ceiling Tile	Deep Fissure	200	Square Feet	15*	None Detected
	Ceiling Tile Adhesive	Tan	200	Square Feet	16*	None Detected
	12" x 12" Ceiling Tile	Fine Pinhole Fissure	70	Square Feet	13*	None Detected
	Ceiling Tile Adhesive	Brown	70	Square Feet	14*	None Detected
	12" x 12" Ceiling Tile	Fine Pinhole Fine Fissure	10	Square Feet	11*	None Detected
	Ceiling Tile Adhesive	Brown	10	Square Feet	12*	2% Anthophyllite
	12" x 12" Floor Tile	Brown mottled	280	Square Feet	55*	None Detected
	Floor Tile Adhesive	Black	280	Square Feet	56*	7% Chrysotile
	Plaster	Wall	130	Square Feet	Not Sampled	Assumed Asbestos
	Sheetrock	Wall and Ceiling	553	Square Feet	Not Sampled	Assumed Asbestos
Ceiling Hatch	1-4" Pipe Insulation	White Fibrous	80	Linear Feet	B0313	10%Chrysotile 40%Amosite 24%Chrysotile 16%Amosite
	1-4" Pipe Fitting Insulation on White Fibrous	White Fibrous	26	Each	B0316	
Conference Room 42-1C	9" x 9" Floor Tile	Red	576	Square Feet	45*	15% Chrysotile
	Floor Tile Adhesive	Black	576	Square Feet	46*	None Detected
	Sheetrock	Wall	900	Square Feet	Not Sampled	Assumed Asbestos
	2' x 2' Ceiling Tile	Splatter	576	Square Feet	23A	None Detected
	Base Board Adhesive	Brown	100	Linear Feet	62*	None Detected
Conference Room 42-1C Storage Room	12" x 12" Ceiling Tile	Rough	48	Square Feet	9*	None Detected
	Ceiling Tile Adhesive	Brown	48	Square Feet	10*	5% Anthophyllite
	Sheetrock	Wall	160	Square Feet	Not Sampled	Assumed Asbestos
	Plaster	Wall and Ceiling	112	Square Feet	Not Sampled	Assumed Asbestos
	9" x 9" Floor Tile	Red	48	Square Feet	45*	15% Chrysotile
	Floor Tile Adhesive	Black	48	Square Feet	46*	None Detected
	Base Board Adhesive	Tan	38	Linear Feet	61*	None Detected
East Office Area	12" x 12" Floor Tile	Brown mottled	56	Square Feet	55*	None Detected
	Floor Tile Adhesive	Black	56	Square Feet	56*	7% Chrysotile
	Sheetrock	Wall	5760	Square Feet	Not Sampled	Assumed Asbestos

* = This result is inferred as consistent with an analyzed sample of the same material from another area.
NSMO = No Suspect Materials Observed.
Samples starting with B are samples taken in previous surveys.

Location	Material Identification	Physical ID	Quantity	Units	Sample #	Results
East Office Area	2' x 2' Ceiling Tile	Splatter	5760	Square Feet	23*	None Detected
	Base Board Adhesive	Tan	920	Linear Feet	61*	None Detected
	9" x 9" Floor Tile	Tan w/ Brown	8200	Square Feet	36A	4% Chrysotile
	Floor Tile Adhesive	Black	8200	Square Feet	37A	5% Chrysotile
	Window Glazings	White	20	Each	73A	2% Chrysotile
	1-4" Pipe Insulation	White Fibrous	156	Linear Feet	B0313	10%Chrysotile 40%Amosite
	1-4" Pipe Fitting Insulation on White Fibrous	White Fibrous	24	Each	B0316	24%Chrysotile 16%Amosite
Conference Room 2	2' x 2' Ceiling Tile	Splatter	240	Square Feet	23*	None Detected
	Base Board Adhesive	Tan	64	Linear Feet	61*	None Detected
	9" x 9" Floor Tile	Red	240	Square Feet	45*	15% Chrysotile
	Floor Tile Adhesive	Black	240	Square Feet	46*	None Detected
	Sheetrock	Wall	576	Square Feet	Not Sampled	Assumed Asbestos
	1-4" Pipe Insulation	White Fibrous	42	Linear Feet	B0313	10%Chrysotile 40%Amosite
	1-4" Pipe Fitting Insulation on White Fibrous	White Fibrous	8	Each	B0316	24%Chrysotile 16%Amosite
East Office Corridor	2' x 2' Ceiling Tile	Splatter	121	Square Feet	23*	None Detected
	12" x 12" Ceiling Tile	Flat	240	Square Feet	17A	None Detected
	Sheetrock	Wall	978	Square Feet	Not Sampled	Assumed Asbestos
	Plaster	Wall and Ceiling	96	Square Feet	Not Sampled	Assumed Asbestos
	12" x 12" Floor Tile	Brown mottled	45	Square Feet	55*	None Detected
	Floor Tile Adhesive	Black	45	Square Feet	56*	7% Chrysotile
East Office Corridor Closet	Sheetrock	Wall	144	Square Feet	Not Sampled	Assumed Asbestos
	12" x 12" Ceiling Tile	Deep Fissure	28	Square Feet	15*	None Detected
	Ceiling Tile Adhesive	Tan	28	Square Feet	16*	None Detected
D-8 Pipe Chase	1-4" Pipe Insulation	Cork	14	Linear Feet	Not Sampled	Assumed Asbestos
	1-4" Pipe Fitting Insulation on Cork	Gray Fibrous	7	Each	Not Sampled	Assumed Asbestos
	1-4" Pipe Insulation	White Fibrous	36	Linear Feet	B0313	10%Chrysotile 40%Amosite

* = This result is inferred as consistent with an analyzed sample of the same material from another area.
NSMO = No Suspect Materials Observed.
Samples starting with B are samples taken in previous surveys.

Location	Material Identification	Physical ID	Quantity	Units	Sample #	Results
East Office Corridor Janitor's Closet	2' x 4' Ceiling Tile	Pinhole Fissure	24	Square Feet	27*	None Detected
	2' x 4' Ceiling Tile	Divot	48	Square Feet	28A	None Detected
Training Room A	12" x 12" Ceiling Tile	Deep Fissure	667	Square Feet	15*	None Detected
	Ceiling Tile Adhesive	Tan	667	Square Feet	16*	None Detected
	12" x 12" Ceiling Tile	Fine Pinhole Fissure	36	Square Feet	13*	None Detected
	Ceiling Tile Adhesive	Brown	36	Square Feet	14*	None Detected
	Plaster	Wall	504	Square Feet	Not Sampled	Assumed Asbestos
	Sheetrock	Wall and Ceiling	1207	Square Feet	Not Sampled	Assumed Asbestos
	Base Board Adhesive	Tan	112	Linear Feet	61*	None Detected
	9" x 9" Floor Tile	Gray w/ White and Black	722	Square Feet	47*	7% Chrysotile
	Floor Tile Adhesive	Black	722	Square Feet	48*	15% Chrysotile
	1-4" Pipe Insulation	White Fibrous	61	Linear Feet	B0313	10%Chrysotile 40%Amosite
	1-4" Pipe Fitting Insulation on White Fibrous	White Fibrous	14	Each	B0316	24%Chrysotile 16%Amosite
Training Room A Storage	12" x 12" Ceiling Tile	Deep Fissure	80	Square Feet	15*	None Detected
	Ceiling Tile Adhesive	Tan	80	Square Feet	16*	None detected
	Sheetrock	Wall	324	Square Feet	Not Sampled	Assumed Asbestos
	9" x 9" Floor Tile	Gray w/ White and Black	80	Square Feet	47*	7% Chrysotile
	Floor Tile Adhesive	Black	80	Square Feet	48*	15% Chrysotile
	Base Board Adhesive	Tan	36	Linear Feet	61*	None detected
B-7 Pipe Chase	1-4" Pipe Insulation	White Fibrous	9	Linear Feet	B0313	10%Chrysotile 40%Amosite
	1-4" Pipe Fitting Insulation on White Fibrous	White Fibrous	3	Each	B0316	24%Chrysotile 16%Amosite
	> 4" Pipe Insulation	White Fibrous	4	Linear Feet	B0307	18%Chrysotile 32%Amosite
	> 4" Pipe Fitting Insulation on White Fibrous	White Fibrous	1	Each	B0310	20%Chrysotile 25%Amosite
Training Room B	2' x 2' Ceiling Tile	Lumpy	440	Square Feet	25A	None Detected

* = This result is inferred as consistent with an analyzed sample of the same material from another area.
NSMO = No Suspect Materials Observed.
Samples starting with B are samples taken in previous surveys.

Location	Material Identification	Physical ID	Quantity	Units	Sample #	Results
Training Room B	Sheetrock	Wall	576	Square Feet	Not Sampled	Assumed Asbestos
	9" x 9" Floor Tile	Tan w/ Brown and White	440	Square Feet	47*	7% Chrysotile
	Floor Tile Adhesive	Black	440	Square Feet	48*	15% Chrysotile
	Base Board Adhesive	Tan	84	Linear Feet	61*	None Detected
	Plaster	Wall	180	Square Feet	Not Sampled	Assumed Asbestos
	1-4" Pipe Insulation	White Fibrous	51	Linear Feet	B0313	10%Chrysotile 40%Amosite
Training Room c	1-4" Pipe Fitting Insulation on White Fibrous	White Fibrous	22	Each	B0316	24%Chrysotile 16%Amosite
	2' x 2' Ceiling Tile	Lumpy Wall	418	Square Feet	25*	None Detected
	Sheetrock	Wall	720	Square Feet	Not Sampled	Assumed Asbestos
	9" x 9" Floor Tile	Cream	418	Square Feet	42A	5% Chrysotile
	Floor Tile Adhesive	Black	418	Square Feet	44A	3% Chrysotile
	Tar Paper	Black	418	Square Feet	43A	None Detected
	Base Board Adhesive	Tan	80	Linear Feet	61*	None Detected
	Cork Wall	Under Plaster	133	Square Feet	5A	None Detected
	Cork Adhesive	Black	133	Square Feet	6A	2% Chrysotile
	Plaster	Wall	108	Square Feet	Not Sampled	Assumed Asbestos
	1-4" Pipe Insulation	White Fibrous	56	Linear Feet	B0313	10%Chrysotile 40%Amosite
Training Room Hallway	1-4" Pipe Fitting Insulation on White Fibrous	White Fibrous	26	Each	B0316	24%Chrysotile 16%Amosite
	2' x 2' Ceiling Tile	Lumpy Wall	110	Square Feet	25*	None Detected
	Sheetrock	Wall	288	Square Feet	Not Sampled	Assumed Asbestos
	Base Board Adhesive	Tan	44	Linear Feet	61*	None Detected
	12" x 12" Floor Tile	Brown mottled	110	Square Feet	55*	None Detected
Conference Room 42-1W	Floor Tile Adhesive	Black	110	Square Feet	56*	7% Chrysotile
	2' x 2' Ceiling Tile	Lumpy Wall	748	Square Feet	25*	None Detected
	Sheetrock	Wall	1008	Square Feet	Not Sampled	Assumed Asbestos
	Base Board Adhesive	Tan	112	Linear Feet	61*	None Detected
9" x 9" Floor Tile	Tan w/ Brown and White	748	Square Feet	47*	7% Chrysotile	

* = This result is inferred as consistent with an analyzed sample of the same material from another area.
NSMO = No Suspect Materials Observed.
Samples starting with B are samples taken in previous surveys.

Location	Material Identification	Physical ID	Quantity	Units	Sample #	Results	
Conference Room 42-1W	Floor Tile Adhesive	Black	748	Square Feet	48*	15% Chrysotile	
West Corridor	12" x 12" Ceiling Tile Ceiling Tile Adhesive 2' x 2' Ceiling Tile Sheetrock Base Board Adhesive Base Board Adhesive 12" x 12" Floor Tile Floor Tile Adhesive	Deep Fissure	1032	Square Feet	15*	None Detected	
		Tan	1032	Square Feet	16*	None Detected	
		Fine	1032	Square Feet	22A	None Detected	
		Wall	1548	Square Feet	Not Sampled	Assumed Asbestos	
		Cream	180	Linear Feet	63A	None Detected	
		Brown	180	Linear Feet	62*	None Detected	
		Brown mottled	1032	Square Feet	55*	None Detected	
		Black	1032	Square Feet	56*	7% Chrysotile	
Fitness Center	2' x 2' Ceiling Tile Plaster Sheetrock Base Board Adhesive Window Glazing 1-4" Pipe Insulation 1-4" Pipe Fitting Insulation on White Fibrous	Lumpy Pinhole	3344	Square Feet	21A	None detected	
		Wall	532	Square Feet	Not Sampled	Assumed Asbestos	
		Wall	140	Square Feet	Not Sampled	Assumed Asbestos	
		Cream	236	Linear Feet	63*	None detected	
		White	15	Each	73*	2% Chrysotile	
		White Fibrous	84	Linear Feet	B0313	10%Chrysotile	
		White Fibrous	38	Each	B0316	40%Amosite	
							24%Chrysotile
A-6 Pipe Chase	1-4" Pipe Insulation 1-4" Pipe Fitting Insulation on White Fibrous	White Fibrous	16	Linear Feet	B0313	10%Chrysotile	
		White Fibrous	6	Each	B0316	40%Amosite	
							24%Chrysotile
							16%Amosite
Aerobics Room	12" x 12" Ceiling Tile Ceiling Tile Adhesive Sheetrock Base Board Adhesive	Deep Fissure	1292	Square Feet	15*	None Detected	
		Tan	1292	Square Feet	16*	None Detected	
		Wall and Ceiling	2552	Square Feet	Not Sampled	Assumed Asbestos	
		Cream	140	Linear Feet	63*	None Detected	
Men's Locker Room	2' x 2' Ceiling Tile Sheetrock Base Board Adhesive Window Glazing	Divot	504	Square Feet	28*	None detected	
		Wall	352	Square Feet	Not Sampled	Assumed Asbestos	
		Cream	44	Linear Feet	63*	None detected	
		White	6	Each	73*	2% Chrysotile	

* = This result is inferred as consistent with an analyzed sample of the same material from another area.
NSMO = No Suspect Materials Observed.
Samples starting with B are samples taken in previous surveys.

Location	Material Identification	Physical ID	Quantity	Units	Sample #	Results
Men's Locker Room	1-4" Pipe Insulation	White Fibrous	50	Linear Feet	B0313	10%Chrysotile 40%Amosite
	1-4" Pipe Fitting Insulation on White Fibrous	White Fibrous	28	Each	B0316	24%Chrysotile 16%Amosite
Women's Locker Room	2' x 2' Ceiling Tile	Divot Wall	286	Square Feet	28*	None Detected
	Sheetrock	Wall	880	Square Feet	Not Sampled	Assumed Asbestos
	Base Board Adhesive	Cream	110	Linear Feet	63*	None Detected
Guards Desk	Plaster	Wall and Ceiling	164	Square Feet	Not Sampled	Assumed Asbestos
East Janitor's Closet	Plaster	Wall and Ceiling	228	Square Feet	Not Sampled	Assumed Asbestos
E-8 Pipe Chase	NSMO					
Supply Room	12" x 12" Ceiling Tile	Rough	192	Square Feet	9*	None Detected
	Ceiling Tile Adhesive	Brown	192	Square Feet	10*	5% Anthophyllite
	12" x 12" Ceiling Tile	Fine Pinhole Fissure	7	Square Feet	13*	None Detected
	Ceiling Tile Adhesive	Brown	7	Square Feet	14*	None Detected
	Plaster	Wall and Ceiling	600	Square Feet	Not Sampled	Assumed Asbestos
	Sheetrock	Wall and Ceiling	112	Square Feet	Not Sampled	Assumed Asbestos
	Base Board Adhesive	Tan	80	Linear Feet	61*	None Detected
	9" x 9" Floor Tile	Red	192	Square Feet	45*	15% Chrysotile
	Floor Tile Adhesive	Black	192	Square Feet	46*	None Detected
C-8 Pipe Chase	1-4" Pipe Insulation	White Fibrous	12	Linear Feet	B0313	10%Chrysotile 40%Amosite
	> 4" Pipe Insulation	Cork	24	Linear Feet	B0326	None Detected
	> 4" Pipe Insulation	White Fibrous	12	Linear Feet	B0307	18%Chrysotile 32%Amosite
Men's Restroom	2' x 2' Ceiling Tile	Divot	286	Square Feet	28*	None Detected
	Plaster	Wall and Ceiling	705	Square Feet	Not Sampled	Assumed Asbestos
	Sheetrock	Wall	40	Square Feet	Not Sampled	Assumed Asbestos
	Base Board Adhesive	Cream	26	Linear Feet	63*	None Detected
	Base Board Adhesive	Brown	26	Linear Feet	62*	None Detected

* = This result is inferred as consistent with an analyzed sample of the same material from another area.
NSMO = No Suspect Materials Observed.
Samples starting with B are samples taken in previous surveys.

Location	Material Identification	Physical ID	Quantity	Units	Sample #	Results
Men's Restroom	12" x 12" Floor Tile	Brown mottled Black	40	Square Feet	55*	None Detected
	Floor Tile Adhesive		40	Square Feet	56*	7% Chrysotile
	1-4" Pipe Insulation	White Fibrous	44	Linear Feet	B0313	10% Chrysotile 40% Amosite
	1-4" Pipe Fitting Insulation on White Fibrous	White Fibrous	12	Each	B0316	24% Chrysotile 16% Amosite
	1-4" Pipe Insulation	Felt	12	Linear Feet	B0337	18% Chrysotile 9% Chrysotile 18% Amosite
	1-4" Pipe Fitting Insulation on Felt	Gray Fibrous	2	Each	B0341	
Company Store	12" x 12" Ceiling Tile	Deep Fissure Tan	2196	Square Feet	15*	None Detected
	Ceiling Tile Adhesive Plaster		2196	Square Feet	16*	None Detected
	Sheetrock	Wall	450	Square Feet	Not Sampled	Assumed Asbestos
	12" x 12" Floor Tile	Wall	928	Square Feet	Not Sampled	Assumed Asbestos
	Floor Tile Adhesive	Brown mottled Black	402	Square Feet	55*	None Detected
	9" x 9" Floor Tile	Gray w/ White and Black	402	Square Feet	56*	7% Chrysotile
	Floor Tile Adhesive	Black	1662	Square Feet	47*	7% Chrysotile
	Base Board Adhesive	Black	1662	Square Feet	48*	15% Chrysotile
		Tan	116	Linear Feet	61*	None Detected
Company Store Office	12" x 12" Ceiling Tile	Deep Fissure Tan	208	Square Feet	15*	None Detected
	Ceiling Tile Adhesive Sheetrock		208	Square Feet	16*	None Detected
	9" x 9" Floor Tile	Wall	174	Square Feet	Not Sampled	Assumed Asbestos
	Floor Tile Adhesive	Gray w/ White and Black	208	Square Feet	47*	7% Chrysotile
		Black	208	Square Feet	48*	15% Chrysotile
Company Store Room	12" x 12" Ceiling Tile	Deep Fissure Tan	396	Square Feet	15*	None Detected
	Ceiling Tile Adhesive Sheetrock		396	Square Feet	16*	None Detected
	9" x 9" Floor Tile	Wall	288	Square Feet	Not Sampled	Assumed Asbestos
	Floor Tile Adhesive	Gray w/ White and Black	396	Square Feet	47*	7% Chrysotile
		Black	396	Square Feet	48*	15% Chrysotile

* = This result is inferred as consistent with an analyzed sample of the same material from another area.
NSMO = No Suspect Materials Observed.
Samples starting with B are samples taken in previous surveys.

Location	Material Identification	Physical ID	Quantity	Units	Sample #	Results
Water Pump Room	Transite Panels	Wall	150	Square Feet	69A	40% Chrysotile
C-4 Training Room	2' x 2' Ceiling Tile	Fine Wall	480	Square Feet	22*	None Detected
	Sheetrock	Yellow	558	Square Feet	Not Sampled	Assumed Asbestos
	Base Board Adhesive	White	62	Linear Feet	64A	None Detected
	Window Glazing		4	Each	73*	2% Chrysotile
	1-4" Pipe Insulation	White Fibrous	21	Linear Feet	B0313	10%Chrysotile 40%Amosite
	1-4" Pipe Fitting Insulation on White Fibrous	White Fibrous	4	Each	B0316	24%Chrysotile 16%Amosite
C-1 Pipe Chase	Inaccessible					
D-1 Pipe Chase	Inaccessible					
A-1 Pipe Chase	1-4" Pipe Insulation	White Fibrous	20	Linear Feet	B0313	10%Chrysotile 40%Amosite
	1-4" Pipe Fitting Insulation on White Fibrous	White Fibrous	4	Each	B0316	24%Chrysotile 16%Amosite
	> 4" Pipe Insulation	White Fibrous	12	Linear Feet	B0307	18%Chrysotile 32%Amosite
F-1 Pipe Chase	1-4" Pipe Insulation	White Fibrous	18	Linear Feet	B0313	10%Chrysotile 40%Amosite
	1-4" Pipe Fitting Insulation on White Fibrous	White Fibrous	2	Each	B0316	24%Chrysotile 16%Amosite
	> 4" Pipe Insulation	White Fibrous	12	Linear Feet	B0307	18%Chrysotile 32%Amosite
Old Restroom	2' x 2' Ceiling Tile	Divot	24	Square Feet	28*	None Detected
	Plaster	Wall and Ceiling	66	Square Feet	Not Sampled	Assumed Asbestos
	1-4" Pipe Insulation	Cork	8	Linear Feet	B0313	10%Chrysotile 40%Amosite
A-8 Pipe Chase	NSMO					

* = This result is inferred as consistent with an analyzed sample of the same material from another area.
NSMO = No Suspect Materials Observed.
Samples starting with B are samples taken in previous surveys.

Location	Material Identification	Physical ID	Quantity	Units	Sample #	Results
Women's Restroom	2' x 2' Ceiling Tile	Divot	280	Square Feet	28*	None Detected
	Plaster	Wall and Ceiling	776	Square Feet	Not Sampled	Assumed Asbestos
	Sheetrock	Wall	56	Square Feet	Not Sampled	Assumed Asbestos
	Base Board Adhesive	Cream	48	Linear Feet	63*	None Detected
	Base Board Adhesive	Brown	48	Linear Feet	62*	None Detected
	12" x 12" Floor Tile	Brown mottled	56	Square Feet	55*	None Detected
	Floor Tile Adhesive	Black	56	Square Feet	56*	7% Chrysotile
Elevator Lobby	12" x 12" Ceiling Tile	Flat	2415	Square Feet	17*	None Detected
	Sheetrock	Wall	2070	Square Feet	Not Sampled	Assumed Asbestos
Separate Guards Desk	12" x 12" Ceiling Tile	Rough	236	Square Feet	9*	None Detected
	Ceiling Tile Adhesive	Brown	236	Square Feet	10*	5% Anthophyllite
	12" x 12" Ceiling Tile	Fine Pinhole Fissure	78	Square Feet	13*	None Detected
	Ceiling Tile Adhesive	Brown	78	Square Feet	14*	None Detected
	Base Board Adhesive	Cream	16	Linear Feet	63*	None Detected
	Sheetrock	Wall	864	Square Feet	Not Sampled	Assumed Asbestos
Housekeeping Office	12" x 12" Ceiling Tile	Rough	228	Square Feet	9*	None Detected
	Ceiling Tile Adhesive	Brown	228	Square Feet	10*	5% Anthophyllite
	9" x 9" Floor Tile	Red	228	Square Feet	45*	15% Chrysotile
	Floor Tile Adhesive	Black	228	Square Feet	46*	None Detected
	Plaster	Wall	152	Square Feet	Not Sampled	Assumed Asbestos
	Sheetrock	Wall and Ceiling	572	Square Feet	Not Sampled	Assumed Asbestos
	Base Board Adhesive	Tan	62	Linear Feet	61*	None Detected
E-9 Pipe Chase	1-4" Pipe Insulation	Felt	4	Linear Feet	B0337	18%Chrysotile
	1-4" Pipe Fitting Insulation on Felt	Gray Fibrous	2	Each	B0341	9%Chrysotile 18%Amosite
West Vestibule	Plaster	Wall	81	Square Feet	Not Sampled	Assumed Asbestos
West Entrance	12" x 12" Ceiling Tile	Deep Fissure	150	Square Feet	15*	None Detected
	Ceiling Tile Adhesive	Tan	150	Square Feet	16*	None Detected
	12" x 12" Ceiling Tile	Fine Pinhole Fine Fissure	30	Square Feet	11*	None Detected

* = This result is inferred as consistent with an analyzed sample of the same material from another area.
NSMO = No Suspect Materials Observed.
Samples starting with B are samples taken in previous surveys.

Location	Material Identification	Physical ID	Quantity	Units	Sample #	Results
West Entrance	Ceiling Tile Adhesive	Brown	30	Square Feet	12*	2% Anthophyllite
	Plaster	Wall	432	Square Feet	Not Sampled	Assumed Asbestos
	Sheetrock	Ceiling	180	Square Feet	Not Sampled	Assumed Asbestos

2nd Floor

West Office Area	12" x 12" Ceiling Tile	Deep Fissure	9653	Square Feet	15*	None Detected
	Ceiling Tile Adhesive	Tan	9653	Square Feet	16*	None Detected
	12" x 12" Ceiling Tile	Fine Pinhole Fissure	3218	Square Feet	13*	None Detected
	Ceiling Tile Adhesive	Brown	3218	Square Feet	14*	None Detected
	Plaster	Wall and Ceiling	12555	Square Feet	Not Sampled	Assumed Asbestos
	Sheetrock	Wall and Ceiling	14832	Square Feet	Not Sampled	Assumed Asbestos
	Window Glazing	White	54	Each	73*	2% Chrysotile
	Base Board Adhesive	Brown	1152	Linear Feet	62*	None Detected
	9" x 9" Floor Tile	Tan w/ Brown and White	12870	Square Feet	47*	7% Chrysotile
	Floor Tile Adhesive	Black	12870	Square Feet	48*	15% Chrysotile
	1-4" Pipe Insulation	White Fibrous	484	Linear Feet	B0313	10% Chrysotile 40% Amosite
	1-4" Pipe Fitting Insulation on White Fibrous	White Fibrous	72	Each	B0316	24% Chrysotile 16% Amosite

West Room	12"x12" Ceiling Tile	Deep Fissure	196	Square Feet	15*	None Detected
	Ceiling Tile Adhesive	Tan	196	Square Feet	16*	None Detected
	12"x12" Ceiling Tile	Fine Pinhole Fissure	12	Square Feet	11*	None Detected
	Ceiling Tile Adhesive	Brown	12	Square Feet	12*	2% Anthophyllite
	9"x9" Floor Tile	Gray w/White and Black	208	Square Feet	47*	7% Chrysotile
	Floor Tile Adhesive	Black	208	Square Feet	48*	15% Chrysotile
	Sheetrock	Wall and Ceiling	613	Square Feet	Not Sampled	Assumed Asbestos
Plaster	Wall	117	Square Feet	Not Sampled	Assumed Asbestos	

D-7 Pipe Chase	Inaccessible					
----------------	--------------	--	--	--	--	--

D-1 Pipe Chase	Inaccessible					
----------------	--------------	--	--	--	--	--

* = This result is inferred as consistent with an analyzed sample of the same material from another area.
NSMO = No Suspect Materials Observed.
Samples starting with B are samples taken in previous surveys.

Location	Material Identification	Physical ID	Quantity	Units	Sample #	Results
F-1 Pipe Chase	1-4" Pipe Insulation	White Fibrous	18	Linear Feet	B0313	10%Chrysotile 40%Amosite
	1-4" Pipe Fitting Insulation on White Fibrous	White Fibrous	4	Each	B0316	24%Chrysotile 16%Amosite
	> 4" Pipe Insulation	White Fibrous	12	Linear Feet	B0307	18%Chrysotile 32%Amosite
	Tar Paper	On Ducting	50	Square Feet	Not Sampled	Assumed Asbestos
C-1 Pipe Chase	1-4" Pipe Insulation	Cork	12	Linear Feet	Not Sampled	Assumed Asbestos
	1-4" Pipe Insulation	White Fibrous	28	Linear Feet	B0313	10%Chrysotile 40%Amosite
	1-4" Pipe Fitting on White Fibrous	White Fibrous	2	Each	B0316	24%Chrysotile 16%Amosite
A-1 Pipe Chase	1-4" Pipe Insulation	White Fibrous	29	Linear Feet	B0313	10%Chrysotile 40%Amosite
	1-4" Pipe Fitting Insulation on White Fibrous	White Fibrous	4	Each	B0316	24%Chrysotile 16%Amosite
	Tar Paper	On Ducting	50	Square Feet	Not Sampled	Assumed Asbestos
A-6 Pipe Chase	1-4" Pipe Insulation	White Fibrous	20	Linear Feet	B0313	10%Chrysotile 40%Amosite
	1-4" Pipe Fitting Insulation on White Fibrous	White Fibrous	4	Each	B0316	24%Chrysotile 16%Amosite
Private Restroom Pipe Chase	1-4" Pipe Insulation	Felt	94	Linear Feet	B0337	18%Chrysotile 9%Chrysotile 18%Amosite
	1-4" Pipe Fitting Insulation on Felt	Gray Fibrous	10	Each	B0341	10%Chrysotile 40%Amosite
	1-4" Pipe Insulation	White Fibrous	22	Linear Feet	B0313	10%Chrysotile 40%Amosite
West Janitor's Closet	12" x 12" Ceiling Tile	Deep Fissure	55	Square Feet	15*	None Detected
	Ceiling Tile Adhesive	Tan	55	Square Feet	16*	None Detected
	Plaster	Wall	256	Square Feet	Not Sampled	Assumed Asbestos
	Sheetrock	Ceiling	55	Square Feet	Not Sampled	Assumed Asbestos

* = This result is inferred as consistent with an analyzed sample of the same material from another area.
NSMO = No Suspect Materials Observed.
Samples starting with B are samples taken in previous surveys.

Location	Material Identification	Physical ID	Quantity	Units	Sample #	Results
West Janitor's Closet	12" x 12" Floor Tile	Brown mottled	55	Square Feet	55*	None Detected
	Floor Tile Adhesive	Black	55	Square Feet	56*	7% Chrysotile

A-8 Pipe Chase						
NSMO						

Men's Restroom	2' x 2' Ceiling Tile	Divot	286	Square Feet	28*	None Detected
	Plaster	Wall and Ceiling	854	Square Feet	Not Sampled	Assumed Asbestos
	Base Board Adhesive	Brown	30	Linear Feet	62*	None Detected
	12" x 12" Floor Tile	Brown mottled	54	Square Feet	55*	None Detected
	Floor Tile Adhesive	Black	54	Square Feet	56*	7% Chrysotile
	1-4" Pipe Insulation	White Fibrous	12	Linear Feet	B0313	10%Chrysotile
1-4" Pipe Insulation	Felt	12	Linear Feet	B0337	40%Amosite	
						18%Chrysotile

A-9 Pipe Chase	1-4" Pipe Insulation	Felt	2	Linear Feet	B0337	18%Chrysotile
	1-4" Pipe Fitting Insulation on Felt	Gray Fibrous	1	Each	B0341	9%Chrysotile
	> 4" Pipe Insulation	Felt	10	Linear Feet	B0331	18%Amosite
						3%Chrysotile

C-8 Pipe Chase	1-4" Pipe Insulation	White Fibrous	10	Linear Feet	B0313	10%Chrysotile
	> 4" Pipe Insulation	White Fibrous	14	Linear Feet	B0307	40%Amosite
	> 4" Pipe Insulation	Cork	20	Linear Feet	B0326	18%Chrysotile
						32%Amosite
						None Detected

E-8 Pipe Chase	1-4" Pipe Insulation	White Fibrous	24	Linear Feet	B0313	10%Chrysotile
	1-4" Pipe Fitting Insulation on White Fibrous	White Fibrous	3	Each	B0316	40%Amosite
	> 4" Pipe Insulation	White Fibrous	14	Linear Feet	B0307	24%Chrysotile
	> 4" Pipe Fitting Insulation on White Fibrous	White Fibrous	3	Each	B0310	16%Amosite
	1-4" Pipe Insulation	Cork	12	Linear Feet	Not Sampled	18%Chrysotile
	1-4" Pipe Fitting Insulation on Cork	Cork	2	Linear Feet	Not Sampled	32%Amosite
						20%Chrysotile
						25%Amosite
						Assumed Asbestos
						Assumed Asbestos

* = This result is inferred as consistent with an analyzed sample of the same material from another area.
NSMO = No Suspect Materials Observed.
Samples starting with B are samples taken in previous surveys.

Location	Material Identification	Physical ID	Quantity	Units	Sample #	Results
Electrical Room	2' x 4' Ceiling Tile	Pinhole Fissure Divot	64	Square Feet	27*	None Detected
	2' x 4' Ceiling Tile		8	Square Feet	28*	None Detected
Women's Restroom	2' x 2' Ceiling Tile Plaster	Divot	264	Square Feet	28*	None Detected
			616	Square Feet	Not Sampled	Assumed Asbestos
	Sheetrock	Wall and Ceiling	88	Square Feet	Not Sampled	Assumed Asbestos
			16	Linear Feet	63*	None Detected
	Base Board Adhesive	Cream	16	Linear Feet	62*	None Detected
			16	Linear Feet		10%Chrysotile
	1-4" Pipe Insulation	White Fibrous	24	Linear Feet	B0313	40%Amosite
	1-4" Pipe Fitting Insulation on White Fibrous	White Fibrous	3	Each	B0316	24%Chrysotile
1-4" Pipe Insulation	Felt	28	Linear Feet	B0337	16%Amosite	
1-4" Pipe Fitting Insulation on Felt	Gray Fibrous	3	Each	B0341	18%Chrysotile	
E-8 Pipe Chase	1-4" Pipe Insulation	White Fibrous	24	Linear Feet	B0313	10%Chrysotile
	1-4" Pipe Fitting Insulation on White Fibrous	White Fibrous	6	Each	B0316	40%Amosite
	1-4" Pipe Insulation	Felt	9	Linear Feet	B0337	24%Chrysotile
	1-4" Pipe Fitting Insulation on Felt	Gray Fibrous	2	Each	B0341	16%Amosite
E-9 Pipe Chase	1-4" Pipe Insulation	White Fibrous	8	Linear Feet	B0313	18%Chrysotile
	1-4" Pipe Fitting Insulation on White Fibrous	White Fibrous	1	Each	B0316	10%Chrysotile
	1-4" Pipe Insulation	Felt	4	Linear Feet	B0337	40%Amosite
	1-4" Pipe Fitting Insulation on Felt	Gray Fibrous	3	Each	B0341	24%Chrysotile
Mail Storage	9" x 9" Floor Tile	Red Black Wall	345	Square Feet	45*	15% Chrysotile
			345	Square Feet	46*	None Detected
	Floor Tile Adhesive Plaster	Wall and Ceiling	424	Square Feet	Not Sampled	Assumed Asbestos
			529	Square Feet	Not Sampled	Assumed Asbestos

* = This result is inferred as consistent with an analyzed sample of the same material from another area.
NSMO = No Suspect Materials Observed.
Samples starting with B are samples taken in previous surveys.

Location	Material Identification	Physical ID	Quantity	Units	Sample #	Results
Mail Storage	Base Board Adhesive	Brown	76	Linear Feet	62*	None Detected
Record Storage	12" x 12" Ceiling Tile	Rough	1125	Square Feet	9*	None Detected
	Ceiling Tile Adhesive	Brown	1125	Square Feet	10*	5% Anthophyllite
	9" x 9" Floor Tile	Red	1125	Square Feet	45*	15% Chrysotile
	Floor Tile Adhesive	Black	1125	Square Feet	46*	None Detected
	Plaster	Wall and Ceiling	1725	Square Feet	Not Sampled	Assumed Asbestos
	Sheetrock	Wall	280	Square Feet	Not Sampled	Assumed Asbestos
	Window Glazing	White	5	Each	73*	2% Chrysotile
	Base Board Adhesive	Yellow	140	Linear Feet	64*	None Detected
A-9 Pipe Chase	Inaccessible					
E-9 Pipe Chase	1-4" Pipe Insulation	Felt	4	Linear Feet	B0337	18%Chrysotile
	1-4" Pipe Fitting Insulation on Felt	Gray Fibrous	2	Each	B0341	9%Chrysotile 18%Amosite
Conference Room 42-2E	2' x 4' Ceiling Tile	Longitudinal Pinhole Fissure	352	Square Feet	29*	None Detected
	Sheetrock	Wall	396	Square Feet	Not Sampled	Assumed Asbestos
	Base Board Adhesive	Cream	76	Linear Feet	63*	None Detected
	Plaster	Wall	288	Square Feet	Not Sampled	Assumed Asbestos
	9" x 9" Floor Tile	Red	352	Square Feet	45*	15% Chrysotile
	Floor Tile Adhesive	Black	352	Square Feet	46*	None Detected
	1-4" Pipe Insulation	White Fibrous	14	Linear Feet	B0313	10%Chrysotile 40%Amosite
	1-4" Pipe Fitting Insulation on White Fibrous	White Fibrous	2	Each	B0316	24%Chrysotile 16%Amosite
Small Office Area	12" x 12" Ceiling Tile	Deep Fissure	966	Square Feet	15*	None Detected
	Ceiling Tile Adhesive	Tan	966	Square Feet	16*	None Detected
	Plaster	Wall and Ceiling	2006	Square Feet	Not Sampled	Assumed Asbestos
	Base Board Adhesive	Cream	130	Linear Feet	63*	None Detected
	9" x 9" Floor Tile	Red	966	Square Feet	45*	15% Chrysotile
	Floor Tile Adhesive	Black	966	Square Feet	46*	None Detected
	Window Glazing	White	10	Each	73*	2% Chrysotile

* = This result is inferred as consistent with an analyzed sample of the same material from another area.
NSMO = No Suspect Materials Observed.
Samples starting with B are samples taken in previous surveys.

Location	Material Identification	Physical ID	Quantity	Units	Sample #	Results
East Office Area	12" x 12" Ceiling Tile	Deep Fissure	11235	Square Feet	15*	None Detected
	Ceiling Tile Adhesive	Tan	11235	Square Feet	16*	None Detected
	12" x 12" Ceiling Tile	Fine Pinhole Fissure	636	Square Feet	13*	None Detected
	Ceiling Tile Adhesive	Brown	636	Square Feet	14*	None Detected
	Plaster	Wall and Ceiling	7997	Square Feet	Not Sampled	Assumed Asbestos
	Sheetrock	Wall and Ceiling	12495	Square Feet	Not Sampled	Assumed Asbestos
	Window Glazing	White	54	Each	73*	2% Chrysotile
	Base Board Adhesive	Cream	1685	Linear Feet	63*	None Detected
	9" x 9" Floor Tile	Tan w/ White and Black	11235	Square Feet	34*	3% Chrysotile
	Floor Tile Adhesive	Black	11235	Square Feet	35*	4% Chrysotile
	Fiberglass Duct Insulation Adhesive	Brown	1200	Square Feet	76A	None Detected
East Room	1-4" Pipe Insulation	White Fibrous	503	Linear Feet	B0313	10%Chrysotile 40%Amosite
	1-4" Pipe Fitting Insulation on White Fibrous	White Fibrous	32	Each	B0316	24%Chrysotile 16%Amosite
	12"x12" Ceiling Tile	Deep Fissure	107	Square Feet	15*	None Detected
	Ceiling Tile Adhesive	Tan	107	Square Feet	16*	None Detected
	12"x12" Ceiling Tile	Fine Pinhole Fine Fissure	25	Square Feet	11*	None Detected
East Vent Shaft	Ceiling Tile Adhesive	Brown	25	Square Feet	12*	2% Anthophillite
	9"x9" Floor Tile	Tan w/Brown	132	Square Feet	36*	4%Chrysotile
	Floor Tile Adhesive	Black	132	Square Feet	37*	5% Chrysotile
	Sheetrock	Wall and Ceiling	414	Square Feet	Not Sampled	Assumed Asbestos
	NSMO					
B-16 Pipe Chase	1-4" Pipe Insulation	White Fibrous	52	Linear Feet	B0313	10%Chrysotile 40%Amosite
	1-4" Pipe Fitting Insulation on White Fibrous	White Fibrous	14	Each	B0316	24%Chrysotile 16%Amosite
	> 4" Pipe Insulation	White Fibrous	14	Linear Feet	B0307	18%Chrysotile 32%Amosite
	Tar Paper	On Ducting	300	Square Feet	Not Sampled	Assumed Asbestos

* = This result is inferred as consistent with an analyzed sample of the same material from another area.
NSMO = No Suspect Materials Observed.
Samples starting with B are samples taken in previous surveys.

Location	Material Identification	Physical ID	Quantity	Units	Sample #	Results
----------	-------------------------	-------------	----------	-------	----------	---------

B-15 Pipe Chase	1-4" Pipe Insulation	Cork	12	Linear Feet	Not Sampled	Assumed Asbestos
-----------------	----------------------	------	----	-------------	-------------	------------------

Elevator Room	NSMO					
---------------	------	--	--	--	--	--

F-16 Pipe Chase	1-4" Pipe Insulation	White Fibrous	14	Linear Feet	B0313	10%Chrysotile 40%Amosite
	1-4" Pipe Fitting Insulation on White Fibrous	White Fibrous	2	Each	B0316	24%Chrysotile 16%Amosite
	> 4" Pipe Insulation	White Fibrous	14	Linear Feet	B0307	18%Chrysotile 32%Amosite
	Tar Paper	On Ducting	150	Square Feet	Not Sampled	Assumed Asbestos

Elevator Lobby	12" x 12" Ceiling Tile	Flat	1878	Square Feet	17*	None Detected
	Sheetrock	Wall	1575	Square Feet	Not Sampled	Assumed Asbestos
	12" x 12" Ceiling Tile	Deep Fissure	38	Square Feet	15*	None Detected
	Ceiling Tile Adhesive	Tan	38	Square Feet	16*	None Detected
	Plaster	Wall	1575	Square Feet	Not Sampled	Assumed Asbestos
	Base Board Adhesive	Cream	350	Linear Feet	63*	None Detected
	12" x 12" Floor Tile	Brown mottled	1916	Square Feet	55*	None Detected
	Floor Tile Adhesive	Black	1916	Square Feet	56*	7% Chrysotile
	1-4" Pipe Insulation	White Fibrous	20	Linear Feet	B0313	10%Chrysotile 40%Amosite
	1-4" Pipe Fitting Insulation on White Fibrous	White Fibrous	2	Each	B0316	24%Chrysotile 16%Amosite

3rd Floor

West Office Area	12" x 12" Ceiling Tile	Deep Fissure	12300	Square Feet	15*	None Detected
	Ceiling Tile Adhesive	Tan	12300	Square Feet	16*	None Detected
	Plaster	Wall and Ceiling	4164	Square Feet	Not Sampled	Assumed Asbestos
	Sheetrock	Wall and Ceiling	4986	Square Feet	Not Sampled	Assumed Asbestos
	Window Glazing	White	53	Each	73*	2% Chrysotile
	Base Board Adhesive	Cream	560	Linear Feet	63*	None Detected
	9" x 9" Floor Tile	Gray w/ White	11856	Square Feet	51*	20% Chrysotile
	Floor Tile Adhesive	Black	11856	Square Feet	52*	15% Chrysotile

* = This result is inferred as consistent with an analyzed sample of the same material from another area.
 NSMO = No Suspect Materials Observed.
 Samples starting with B are samples taken in previous surveys.

Location	Material Identification	Physical ID	Quantity	Units	Sample #	Results
West Office Area	1-4" Pipe Insulation	White Fibrous	504	Linear Feet	B0313	10%Chrysotile 40%Amosite
	1-4" Pipe Fitting Insulation on White Fibrous	White Fibrous	72	Each	B0316	24%Chrysotile 16%Amosite
West Room	Plaster	Wall	405	Square Feet	Not Sampled	Assumed Asbestos
	Sheetrock	Wall	405	Square Feet	Not Sampled	Assumed Asbestos
	9"x9" Floor Tile	Gray w/White and Black	208	Square Feet	47*	7% Chrysotile
	Floor Tile Adhesive	Black	208	Square Feet	48*	15% Chrysotile
D-7 Pipe Chase	1-4" Pipe Insulation	White Fibrous	10	Linear Feet	B0313	10%Chrysotile 40%Amosite
C-1 Pipe Chase	1-4" Pipe Insulation	White Fibrous	28	Linear Feet	B0313	10%Chrysotile 40%Amosite
	1-4" Pipe Insulation	Cork	18	Linear Feet	Not Sampled	Assumed Asbestos
	1-4" Pipe Fitting Insulation on Cork	Cork	1	Linear Feet	Not Sampled	Assumed Asbestos
F-1 Pipe Chase	1-4" Pipe Insulation	White Fibrous	20	Linear Feet	B0313	10%Chrysotile 40%Amosite
	1-4" Pipe Fitting Insulation on White Fibrous	White Fibrous	4	Each	B0316	24%Chrysotile 16%Amosite
	> 4" Pipe Insulation	White Fibrous	14	Linear Feet	B0307	18%Chrysotile 32%Amosite
A-1 Pipe Chase	Inaccessible					
Computer Room	12" x 12" Ceiling Tile	Deep Fissure	194	Square Feet	15*	None Detected
	Ceiling Tile Adhesive	Tan	194	Square Feet	16*	None Detected
	12" x 12" Ceiling Tile	Fine Pinhole Fissure	6	Square Feet	13*	None Detected
	Ceiling Tile Adhesive	Brown	6	Square Feet	14*	None Detected
	Plaster	Wall and Ceiling	480	Square Feet	Not Sampled	Assumed Asbestos
	9" x 9" Floor Tile	Gray w/ White	198	Square Feet	51A	20% Chrysotile
	Floor Tile Adhesive	Black	198	Square Feet	52A	15% Chrysotile
	9" x 9" Floor Tile	White w/ Black	2	Square Feet	53A	18% Chrysotile

* = This result is inferred as consistent with an analyzed sample of the same material from another area.
NSMO = No Suspect Materials Observed.
Samples starting with B are samples taken in previous surveys.

Location	Material Identification	Physical ID	Quantity	Units	Sample #	Results	
Computer Room	Floor Tile Adhesive	Black	2	Square Feet	54A	7% Chrysotile	
	Base Board Adhesive	Tan	60	Linear Feet	61*	None Detected	
Small Office Area	12" x 12" Ceiling Tile	Rough	408	Square Feet	9*	None Detected	
	Ceiling Tile Adhesive	Brown	408	Square Feet	10*	5% Anthophyllite	
	12" x 12" Ceiling Tile	Deep Fissure	306	Square Feet	15*	None detected	
	Ceiling Tile Adhesive	Tan	306	Square Feet	16*	None detected	
	Plaster	Wall and Ceiling	1588	Square Feet	Not Sampled	Assumed Asbestos	
	Window Glazing	White	10	Each	73*	2% Chrysotile	
	Base Board Adhesive	Cream	101	Linear Feet	63*	None Detected	
	9" x 9" Floor Tile	Gray w/ White	408	Square Feet	51*	20% Chrysotile	
	Floor Tile Adhesive	Black	408	Square Feet	52*	15% Chrysotile	
	1-4" Pipe Insulation	White Fibrous	56	Linear Feet	B0313	10%Chrysotile 40%Amosite	
	1-4" Pipe Fitting Insulation on White Fibrous	White Fibrous	2	Each	B0316	24%Chrysotile 16%Amosite	
	Conference Room	12" x 12" Ceiling Tile	Rough	264	Square Feet	9*	None Detected
		Ceiling Tile Adhesive	Brown	264	Square Feet	10*	5% Anthophyllite
Plaster		Wall	162	Square Feet	Not Sampled	Assumed Asbestos	
Sheetrock		Wall	272	Square Feet	Not Sampled	Assumed Asbestos	
Window Glazing		White	5	Each	73*	2% Chrysotile	
Base Board Adhesive		Cream	34	Linear Feet	63*	None Detected	
9" x 9" Floor Tile		Red	264	Square Feet	45*	15% Chrysotile	
Floor Tile Adhesive		Black	264	Square Feet	46*	None Detected	
1-4" Pipe Insulation		White Fibrous	46	Linear Feet	B0313	10%Chrysotile 40%Amosite	
1-4" Pipe Fitting Insulation on White Fibrous		White Fibrous	4	Each	B0316	24%Chrysotile 16%Amosite	
> 4" Pipe Insulation		White Fibrous	11	Linear Feet	B0307	18%Chrysotile 32%Amosite	
> 4" Pipe Fitting Insulation on White Fibrous		White Fibrous	1	Each	B0310	20%Chrysotile 25%Amosite	
1-4" Pipe Insulation		Cork	22	Linear Feet	Not Sampled	Assumed Asbestos	
E-8 Pipe Chase		NSMO					

* = This result is inferred as consistent with an analyzed sample of the same material from another area.
NSMO = No Suspect Materials Observed.
Samples starting with B are samples taken in previous surveys.

Location	Material Identification	Physical ID	Quantity	Units	Sample #	Results
Conference Room	1-4" Pipe Fitting Insulation on Cork	Cork	2	Linear Feet	Not Sampled	Assumed Asbestos
South Center Office Area	12" x 12" Ceiling Tile	Rough	861	Square Feet	9*	None Detected
	Ceiling Tile Adhesive	Brown	861	Square Feet	10*	5% Anthrophyllite
	Plaster	Wall	1261	Square Feet	Not Sampled	Assumed Asbestos
	Sheetrock	Wall	110	Square Feet	Not Sampled	Assumed Asbestos
	Base Board Adhesive	Yellow	124	Linear Feet	64*	None Detected
	9" x 9" Floor Tile	Red	861	Square Feet	45*	15% Chrysotile
	Floor Tile Adhesive	Black	861	Square Feet	46*	None Detected
	9" x 9" Floor Tile	Gray w/ White	49	Square Feet	51*	20% Chrysotile
	Floor Tile Adhesive	Black	49	Square Feet	52*	15% Chrysotile
	1-4" Pipe Insulation	White Fibrous	83	Linear Feet	B0313	10%Chrysotile 40%Amosite
> 4" Pipe Insulation	Cork	82	Linear Feet	B0326	None Detected	
D-8 Pipe Chase	1-4" Pipe Insulation	White Fibrous	12	Linear Feet	B0313	10%Chrysotile 40%Amosite
	> 4" Pipe Insulation	White Fibrous	14	Linear Feet	B0307	18%Chrysotile 32%Amosite
	> 4" Pipe Fitting Insulation on White Fibrous	White Fibrous	2	Each	B0310	20%Chrysotile 25%Amosite
	1-4" Pipe Insulation	Cork	16	Linear Feet	Not Sampled	Assumed Asbestos
	1-4" Pipe Fitting Insulation on Cork	Cork	1	Linear Feet	Not Sampled	Assumed Asbestos
E-9 Pipe Chase	NSMO					
Janitor's Closet	2' x 4' Ceiling Tile	Pinhole Fissure	48	Square Feet	27*	None Detected
	2' x 4' Ceiling Tile	Divot	8	Square Feet	28*	None Detected
Men's Restroom	2' x 2' Ceiling Tile	Fine	286	Square Feet	22*	None Detected
	Base Board Adhesive	Tan	28	Linear Feet	61*	None Detected
	Base Board Adhesive	Brown	28	Linear Feet	62*	None Detected
	Plaster	Wall and Ceiling	272	Square Feet	Not Sampled	Assumed Asbestos
	Sheetrock	Wall	630	Square Feet	Not Sampled	Assumed Asbestos
	12" x 12" Floor Tile	Brown mottled	48	Square Feet	55*	None Detected
Floor Tile Adhesive	Black	48	Square Feet	56*	7% Chrysotile	

* = This result is inferred as consistent with an analyzed sample of the same material from another area.
NSMO = No Suspect Materials Observed.
Samples starting with B are samples taken in previous surveys.

Location	Material Identification	Physical ID	Quantity	Units	Sample #	Results
A-9 Pipe Chase	NSMO					
A-8 Pipe Chase	NSMO					
C-8 Pipe Chase	> 4" Pipe Insulation	White Fibrous	14	Linear Feet	B0307	18%Chrysotile 32%Amosite
	> 4" Pipe Insulation	Cork	82	Linear Feet	B0326	None Detected
	> 4" Pipe Fitting Insulation on Cork	Gray Fibrous	12	Each	B0328	17%Chrysotile 16%Amosite
Women's Restroom	2' x 2' Ceiling Tile	Divot	240	Square Feet	28*	None Detected
	Base Board Adhesive	Cream	36	Linear Feet	63*	None Detected
	Plaster	Wall and Ceiling	360	Square Feet	Not Sampled	Assumed Asbestos
	Sheetrock	Wall	576	Square Feet	Not Sampled	Assumed Asbestos
	12" x 12" Floor Tile	Brown mottled	72	Square Feet	55*	None Detected
	Floor Tile Adhesive	Black	72	Square Feet	56*	7% Chrysotile
North Center Office Area	> 4" Pipe Insulation	White Fibrous	6	Linear Feet	B0307	18%Chrysotile 32%Amosite
	12" x 12" Ceiling Tile	Rough	1232	Square Feet	9*	None Detected
	Ceiling Tile Adhesive	Brown	1232	Square Feet	10*	5% Anthophyllite
	Plaster	Wall and Ceiling	2160	Square Feet	Not Sampled	Assumed Asbestos
	Sheetrock	Wall	528	Square Feet	Not Sampled	Assumed Asbestos
	Base Board Adhesive	Yellow	276	Linear Feet	64*	None Detected
	9" x 9" Floor Tile	Red	1232	Square Feet	45*	15% Chrysotile
	Floor Tile Adhesive	Black	1232	Square Feet	46*	None Detected
	Window Glazing	White	5	Each	73*	2% Chrysotile
	East Office Area	12" x 12" Ceiling Tile	Deep Fissure	13104	Square Feet	15*
Ceiling Tile Adhesive		Tan	13104	Square Feet	16*	None Detected
Plaster		Wall	2250	Square Feet	Not Sampled	Assumed Asbestos
Sheetrock		Wall and Ceiling	13956	Square Feet	Not Sampled	Assumed Asbestos
Window Glazing		White	54	Each	73*	2% Chrysotile
Base Board Adhesive		Cream	570	Linear Feet	63*	None Detected

* = This result is inferred as consistent with an analyzed sample of the same material from another area.
NSMO = No Suspect Materials Observed.
Samples starting with B are samples taken in previous surveys.

Location	Material Identification	Physical ID	Quantity	Units	Sample #	Results
East Office Area	9" x 9" Floor Tile	Gray w/ White and Black	722	Square Feet	47*	7% Chrysotile
	Floor Tile Adhesive	Black	722	Square Feet	48*	15% Chrysotile
	1-4" Pipe Insulation	White Fibrous	508	Linear Feet	B0313	10% Chrysotile 40% Amosite
	1-4" Pipe Fitting Insulation on White Fibrous	White Fibrous	64	Each	B0316	24% Chrysotile 16% Amosite
	> 4" Pipe Insulation	White Fibrous	23	Linear Feet	B0307	18% Chrysotile 32% Amosite

East Room	Sheetrock	Wall	414	Square Feet	Not Sampled	Assumed Asbestos
	9"x9" Floor Tile	Gray w/White and Black	132	Square Feet	47*	7% Chrysotile
	Floor Tile Adhesive	Black	132	Square Feet	48*	15% Chrysotile
	Tar on Duct	Black	30	Square Feet	75*	4% Chrysotile

F-16 Pipe Chase	1-4" Pipe Insulation	White Fibrous	18	Linear Feet	B0313	10% Chrysotile 40% Amosite
	1-4" Pipe Fitting Insulation on White Fibrous	White Fibrous	4	Each	B0316	24% Chrysotile 16% Amosite
	> 4" Pipe Insulation	White Fibrous	12	Linear Feet	B0307	18% Chrysotile 32% Amosite

B-16 Pipe Chase	1-4" Pipe Insulation	White Fibrous	52	Linear Feet	B0313	10% Chrysotile 40% Amosite
	1-4" Pipe Fitting Insulation on White Fibrous	White Fibrous	14	Each	B0316	24% Chrysotile 16% Amosite
	> 4" Pipe Insulation	White Fibrous	14	Linear Feet	B0307	18% Chrysotile 32% Amosite
	Tar Paper	On Ducting	300	Square Feet	Not Sampled	Assumed Asbestos

B-15 Pipe Chase	1-4" Pipe Insulation	Cork	14	Linear Feet	Not Sampled	Assumed Asbestos
-----------------	----------------------	------	----	-------------	-------------	------------------

Elevator Room	NSMO					
---------------	------	--	--	--	--	--

Elevator Lobby	12" x 12" Ceiling Tile	Flat	1395	Square Feet	17*	None Detected
----------------	------------------------	------	------	-------------	-----	---------------

* = This result is inferred as consistent with an analyzed sample of the same material from another area.
NSMO = No Suspect Materials Observed.
Samples starting with B are samples taken in previous surveys.